

December 21, 2018

## NOTICE TO ALL PROSPECTIVE BIDDERS

**RE: ADDENDUM 1  
2018-EDW-72  
Wellington WWTP Upgrades and Building Improvements**

This Addendum is being issued to change and/or provide clarification and additional requirements for the specifications of the unit to be bid. The changes are summarized below.

### Questions/Answers

- Proponents are advised that the RFP Closing date has been extended to 02:00 PM of January 16<sup>th</sup>, 2019.
- As a clarification, the Tender validity period identified in Clause 1.g under Standard Terms and Conditions, governs this tender.
- Add Meadow-crete (GPS or OV) to Concrete Repair Mortar products under Clause 2.1 Materials in Section 03730 –Concrete Repairs.
- Clarification about the Stainless steel piping type specified in Clause 2.2 Stainless Steel Piping and Fittings of Section 11500.

Proponents are advised that the piping material shall be 316 L as identified in Drawing P104.

- Delete the contents under Clause 1.12 System Integrators in Section 16700 – Instrumentation and Control in its entirety, and replace as follows:

The supply, installation, and commissioning of instruments and control system hardware and licenses must be performed as a complete package by an experienced and reputable control system supplier firm. The commissioning and startup of individual pieces of equipment is to be performed by a qualified factory trained manufacturer's representative. The following is a list of acceptable control system suppliers:

- i. Summa Engineering 905-678-3388
- ii. Selectra Controls 519-271-0322
- iii. Sirron Systems 888-474-7766

The software programming for the PLC, HMI, and report development services will be completed by the SCADA system programmer, Eramosa Engineering as retained by the contractor.



**The County**

PRINCE EDWARD COUNTY • ONTARIO

December 21, 2018

The general contractor shall co-ordinate all trades, including but not limited to the control system supplier and SCADA system programmer, for the required startup of the new systems as specified.

**PLEASE SIGN AND FAX BACK TO 613.476.7622 or  
E-Mail TO [pwhite@pecounty.on.ca](mailto:pwhite@pecounty.on.ca)**

\_\_\_\_\_  
Received by (Company Name)

\_\_\_\_\_  
Date, Time

**ADDENDUM MUST BE INCLUDED WITH TENDER SUBMISSION**

