

August 15, 2019

NOTICE TO ALL PROSPECTIVE BIDDERS

**RE: ADDENDUM 1
2019-EDW-45
Supply and Installation of 3 New Playgrounds**

This Addendum is being issued to change and/or provide clarification and additional requirements for the specifications of the unit to be bid. The changes are summarized below.

Questions/Answers

1. On page 21 of 30, item 1.1 you state that the equipment must be barrier free. On the same page, item 1.2 you state sand surface must be brought into compliance for surface compaction 200GMAX & 1000HIC.

Sand is not an accessible surface do you anticipate the surfacing being changed to engineered wood fibre or similar accessible surfacing within these budgets which would also require excavation?

On page 21 of 30, item 1.9 you state the play equipment shall be clearly stamped as CSA approved and date stamped. Do you require a 3rd party CSA inspection report be included in these budgets?

The County will be removing the sand and creating a depth of 12 inches– Site A, B, and C - area will be excavated according to the accepted proposal footprint.

Please follow CAN/CSA Z614 Annex H for Accessibility Standard.

Do not replace surface with sand.

The County will have a 3rd party conduct the Inspection once installation is complete.

2. Will surfacing stay as sand or be Engineered Wood Fiber?
If changing to EWF- will The County be responsible for removing the sand?

Follow CAN/CSA Z614 Annex H for accessibility standard for surfacing.
Do not replace with sand.

3. Will 3 1/2 inch post be acceptable- I can provide specs with tensile strength of posts if required.

3.5 inch posts are acceptable.

August 15, 2019

4. Can the closing date be extended?

The closing date has been extended to August 28th at 2:00 p.m.

The completion date for all 3 sites has been extended to October 25th, 2019.

PLEASE SIGN AND SEND BACK TO 613.476.7622

Received by (Company Name)

Date, Time

ADDENDUM MUST BE INCLUDED WITH TENDER SUBMISSION